CUSTOMER ASSISTANCE GUIDE BUILDING PERMIT APPLICATION SUBMITTAL REQUIREMENTS

SWIMMING POOLS (IN-GROUND OR ABOVE-GROUND), SPAS AND HOT TUBS (CONTAINS WATER OVER 24 INCHES DEEP)

- Please read all of the following information.
- The following is a check list. You must have a "checkmark" in all the sections listed below prior to submitting your application.

•	
"Affidavit of Exemption" (See attached form) If you are hiring a contractor to construction, and they have workers' compensation, have the contractor or their insurance carrier p with a "Certificate of Insurance" showing proof of such. If the homeowner or a contractor w workers' compensation is constructing the pool, the attached form must be completed and in	rovide us ithout
A site plan showing the proposed pool, hot tub or spa location including the distance to the front, sides and rear property lines.	s in feet,
Three (3) sets of complete construction documents that <u>show in detail</u> code complia of the work proposed to include <u>but not limited</u> to the following information;	nce for all
Safety barrier – show type for your specific pool installation, (fence, walls, etc including height. (Barrier requirements attached). If installing deck at pool – take submittal requirements for deck also. Electrical service (pump, filter, receptacles, etc.) show location and type of w method. (Electrical requirements attached).	. •
Completed building permit application.	

MDIA will review plans submitted to determine code compliance. If the minimum submittal requirements are not met, we will ask the applicant to supply additional information. If the minimum requirements are met, the plans will be marked "approved". A building permit will be issued and the applicant will be notified of the inspection fees and when they can pick-up the permit at the Municipal Building. All fees shall be paid prior to the issuance of the permit. Then use the inspection procedures provided to have all of the required inspections performed.

INSPECTION PROCEDURES SWIMMING POOLS, SPAS AND HOT TUBS

- Building permit must be posted on the site of the work and clearly visible from the road until completion of the project.
- Your approved plans must be available at all times for inspections. These are the plans that were submitted with your application and were marked "Approved" by the Building Code Official.
- The permit applicant or authorized agent is responsible for scheduling all inspections.
- DO NOT schedule an inspection if the work is not ready!!!!
- When scheduling an inspection, you must supply your permit number to the inspector.

MINIMUM OF 24 HOUR NOTICE REQUIRED TO MIDDLE DEPARTMENT INSPECTION AGENCY, INC.

ALL POOLS:

Electrical Inspection – A. Bonding all metal parts (rebar if concrete, ladder, etc)
associated with pool prior to placing concrete. B. Underground to be inspected prior
to cover.

Inspector, Mark Reese

Phone. 1-866-884-6343

- 2. If Installing Deck Around Or Next To Pool Use inspection procedure for decks also. Inspector, Mark Reese Phone, 1-866-884-6343
- 3. Safety Barrier Inspection Done prior to filling pool with water. Inspector, Mark Reese Phone, 1-866-884-6343
- 4. Final Electrical.

 Inspector, Mark Reese

Phone, 1-866-884-6343

APPENDIX G SWIMMING POOLS, SPAS AND HOT TUBS

SECTION AG101 GENERAL

AG101.1 General. The provisions of this appendix shall control the design and construction of swimming pools, spas and hot tubs installed in or on the lot of a one- or two-family dwelling.

SECTION AG102 DEFINITIONS

AG102.1 General. For the purposes of these requirements, the terms used shall be defined as follows and as set forth in Chapter 2.

ABOVE-GROUND/ON-GROUND POOL. See "Swimming pool."

BARRIER. A fence, wall, building wall or combination thereof which completely surrounds the swimming pool and obstructs access to the swimming pool.

HOT TUB. See "Swimming pool."

IN-GROUND POOL. See "Swimming pool."

RESIDENTIAL. That which is situated on the premises of a detached one- or two-family dwelling or a one-family town house not more than three stories in height.

SPA, NONPORTABLE. See "Swimming pool."

SPA, PORTABLE. A nonpermanent structure intended for recreational bathing, in which all controls, water-heating and water-circulating equipment are an integral part of the product.

SWIMMING POOL. Any structure intended for swimming or recreational bathing that contains water over 24 inches (610 mm) deep. This includes in-ground, above-ground and on-ground swimming pools, hot tubs and spas.

SWIMMING POOL, INDOOR. A swimming pool which is totally contained within a structure and surrounded on all four sides by the walls of the enclosing structure.

SWIMMING POOL, OUTDOOR. Any swimming pool which is not an indoor pool.

SECTION AG103 SWIMMING POOLS

AG103.1 In-ground pools. In-ground pools shall be designed and constructed in conformance with ANSI/NSPI-5 as listed in Section AG108.

AG103.2 Above-ground and on-ground pools. Above-ground and on-ground pools shall be designed and

constructed in conformance with ANSI/NSPI-4 as listed in Section AG108.

SECTION AG104 SPAS AND HOT TUBS

AG104.1 Permanently installed spas and hot tubs. Permanently installed spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-3 as listed in Section AG108.

AG104.2 Portable spas and hot tubs. Portable spas and hot tubs shall be designed and constructed in conformance with ANSI/NSPI-6 as listed in Section AG108.

SECTION AG105 BARRIER REQUIREMENTS

AG105.1 Application. The provisions of this chapter shall control the design of barriers for residential swimming pools, spas and hot tubs. These design controls are intended to provide protection against potential drownings and near-drownings by restricting access to swimming pools, spas and hot tubs.

AG105.2 Outdoor swimming pool. An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa shall be surrounded by a barrier which shall comply with the following:

- 1. The top of the barrier shall be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier shall be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an above-ground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier shall be 4 inches (102 mm).
- 2. Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.
- Solid barriers which do not have openings, such as a masonry or stone wall, shall not contain indentations or protrusions except for normal construction tolerances and tooled masonry joints.
- 4. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the swimming pool side of the fence. Spacing between vertical members shall not exceed 1 3/4 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 3/4 inches (44 mm) in width.

APPENDIX G

- 5. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 1 ¾ inches (44 mm) in width.
- 6. Maximum mesh size for chain link fences shall be a 2 ¼ inch (57 mm) square unless the fence has slats fastened at the top or the bottom which reduce the openings to not more than 1 ¾ inches (44 mm).
- 7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members shall not be more than 1 ¾ inches (44 mm).
- 8. Access gates shall comply with the requirements of Section AG105.2, Items 1 through 7, and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool and shall be self-closing and have a self-latching device. Gates other than pedestrian access gates shall have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, the release mechanism and openings shall comply with the following:
 - 8.1. The release mechanism shall be located on the pool side of the gate at least 3 inches (76 mm) below the top of the gate; and
 - 8.2. The gate and barrier shall have no opening larger than ½ inch (13 mm) within 18 inches (457 mm) of the release mechanism.
- Where a wall of a dwelling serves as part of the barrier, one of the following conditions shall be met:
 - 9.1. The pool shall be equipped with a powered safety cover in compliance with ASTM F1346; or
 - 9.2. Doors with direct access to the pool through that wall shall be equipped with an alarm which produces an audible warning when the door and/or its screen, if present, are opened. The alarm shall be listed in accordance with UL 2017. The audible alarm shall activate within 7 seconds and sound continuously for a minimum of 30 seconds after the door and/or its screen, if present, are opened and be capable of being heard throughout the house during normal household activities. The alarm shall automatically reset under all conditions. The alarm system shall be equipped with a manual means, such as touch pad or switch, to temporarily deactivate the alarm for a single opening. Deactivation shall last for not more than 15 seconds. The deactivation switch(es) shall be located at least 54 inches (1372 mm) above the threshold of the door; or
 - 9.3. Other means of protection, such as self-closing doors with self-latching devices, which are approved by the governing body, shall be acceptable so long as the degree of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described above.

- 10. Where an above-ground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps:
 - 10.1. The ladder or steps shall be capable of being secured, locked or removed to prevent access; or
 - 10.2. The ladder or steps shall be surrounded by a barrier which meets the requirements of Section AG105.2, Items 1 through 9. When the ladder or steps are secured, locked or removed, any opening created shall not allow the passage of a 4-inch-diameter (102 mm) sphere.

AG105.3 Indoor swimming pool. Walls surrounding an indoor swimming pool shall comply with Section AG105.2, Item 9.

AG105.4 Prohibited locations. Barriers shall be located to prohibit permanent structures, equipment or similar objects from being used to climb them.

AG105.5 Barrier exceptions. Spas or hot tubs with a safety cover which complies with ASTM F 1346, as listed in Section AG107, shall be exempt from the provisions of this appendix.

SECTION AG106 ENTRAPMENT PROTECTION FOR SWIMMING POOL AND SPA SUCTION OUTLETS

AG106.1 General. Suction outlets shall be designed to produce circulation throughout the pool or spa. Single-outlet systems, such as automatic vacuum cleaner systems, or multiple suction outlets, whether isolated by valves or otherwise, shall be protected against user entrapment,

AG106.2 Suction fittings. Pool and spa suction outlets shall have a cover that conforms to ANSI/ASME Al 12.19.8M, or an 18 inch x 23inch(457 mm by 584 mm)drain grate or larger, or an approved channel drain system.

Exception: Surface skimmers

AG106.3 Atmospheric vacuum relief system required. Pool and spa single- or multiple-outlet circulation systems shall be equipped with atmospheric vacuum relief should grate covers located therein become missing or broken. This vacuum relief system shall include at least one approved or engineered method of the type specified herein, as follows:

- Safety vacuum release system conforming to ASME Al 12.19.17; or
- An approved gravity drainage system.

AG106.4 Dual drain separation. Single or multiple pump circulation systems have a minimum of two suction outlets of the approved type. A minimum horizontal or vertical distance of 3 feet (914 mm) shall separate the outlets. These suction outlets shall be piped so that water is drawn through them simultaneously through a vacuum-relief-protected line to the pump or pumps.

AG106.5 Pool cleaner fittings. Where provided, vacuum or pressure cleaner fitting(s) shall be located in an accessible position(s) at least 6 inches (152 mm) and not more than 12 inches (305 mm) below the minimum operational water level or as an attachment to the skimmer(s).

SECTION AG107 ABBREVIATIONS

AG107.1 General.


ANSI—American National Standards Institute
11 West 42nd Street, New York, NY 10036
ASME—American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990
ASTM—ASTM International
100 Barr Harbor Drive, West Conshohocken, PA 19428
NSPI—National Spa and Pool Institute
2111 Eisenhower Avenue, Alexandria, VA 22314
UL—Underwriters Laboratories, Inc.
333 Pfingsten Road
Northbrook, Illinois 60062-2096

SECTION AG108 STANDARDS

AG108.1 General. ANSI/NSPI

ANSI/NSPI-3-99 Standard for Permanently Installed
Residential Spas
ANSI/NSPI-4-99 Standard for Above-ground/On-ground
Residential Swimming Pools
ANSI/NSPI-5-99 Standard for Residential In-ground
Swimming Pools
ANSI/NSPI-6-99 Standard for Residential
Portable Spas
ANSI/NSPI-5-2003 Standard for Residential
In-ground Swimming Pools
ANSI/ASME A112.19.8M-1987 (R1996) Suction
Fittings for Use in Swimming Pools,
Wading Pools, Spas, Hot Tubs and
Whirlpool Bathing Appliances
ASTM
ASTM F 1346-91 (2003) Performance Specification
for Safety Covers and Labeling Requirements for
All Covers for Swimming Pools, Spas and
Hot Tubs
ASME
ASME A112.19.17 Manufacturers Safety Vacuum
Release Systems (SVRS) for Residential and
Commercial Swimming Pool, Spa, Hot Tub and
Wading Pool
UL
UL2017-2000 Standard for General-purpose
Signaling Devices & Systems-with Revisions

Through June 2004..... AG105.2



THIS FORM REQUIRES A NOTARY SEAL

AFFIDAVIT OF EXEMPTION

	he provisions of Peni	not required to provide workers compensa nsylvania's Workers' Compensation Law fo	
perform any work	pursuant to building urance to the municip	own work. If property owner does hire con permit, contractor must provide proof of wo pality. Homeowner assumes liability for co	orkers'
	rm work pursuant to	s. Contractor prohibited by law from employs. this building permit unless contractor provi	
	mpt from workers' co	the Workers' Compensation Law. All emplompensation insurance (attach copies of re	
Signature of Appli			
			•
County of	· · · · · · · · · · · · · · · · · · ·		
Municipality of			
		Subscribed, sworn to and acknowledged before me by the above this Day of 20	
SEAL			
		Notary Public	•